

LEAD TESTING RESULTS

Dec-17

ISBE ID	BUILDING ID	BUILDING DESCRIPTION	SAMPLE DATE	SAMPLE TIME	COLLECTED BY	SAMPLE ID NUMBER	SAMPLE LOCATION DESCRIPTION	FIXTURE TYPE	DATE OF LAST USE	TIME OF LAST USE	SAMPLE TYPE	SAMPLE VOLUME(ml)	LabName	MethodName	CONCENTRATION(ug/l)	ReportingLevel(ug/l)
			11/14/2017	06:05	Jeff Carrington	7112781-01	Kitchen Faucet #1 1st					250	PDC Laboratories, Inc.	EPA 200.8	6.64	1.00
			11/14/2017	06:05	Jeff Carrington	7112781-02	Kitchen Faucet #1 2nd					250	PDC Laboratories, Inc.	EPA 200.8	5.27	1.00
			11/14/2017	06:11	Jeff Carrington	7112781-03	Kitchen Faucet #2 1st					250	PDC Laboratories, Inc.	EPA 200.8	9.52	1.00
			11/14/2017	06:11	Jeff Carrington	7112781-04	Kitchen Faucet #2 2nd					250	PDC Laboratories, Inc.	EPA 200.8	3.95	1.00
			11/14/2017	06:17	Jeff Carrington	7112781-05	Hallway Drinking Faucet #1 1st					250	PDC Laboratories, Inc.	EPA 200.8	5.56	1.00
			11/14/2017	06:17	Jeff Carrington	7112781-06	Hallway Drinking Faucet #1 2nd					250	PDC Laboratories, Inc.	EPA 200.8	5.26	1.00
			11/14/2017	06:25	Jeff Carrington	7112781-07	Hallway Drinking Faucet #2 1st					250	PDC Laboratories, Inc.	EPA 200.8	23.9	1.00
			11/14/2017	06:25	Jeff Carrington	7112781-08	Hallway Drinking Faucet #2 2nd					250	PDC Laboratories, Inc.	EPA 200.8	19.6	1.00
			11/14/2017	06:30	Jeff Carrington	7112781-09	Nurses Office FAucet #1 1st					250	PDC Laboratories, Inc.	EPA 200.8	5.70	1.00
			11/14/2017	06:30	Jeff Carrington	7112781-10	Nurses Office FAucet #1 2nd					250	PDC Laboratories, Inc.	EPA 200.8	2.18	1.00

LEAD TESTING RESULTS

Mar-18

ISBE ID	BUILDING ID	BUILDING DESCRIPTION	SAMPLE DATE	SAMPLE TIME	COLLECTED BY	SAMPLE ID NUMBER	SAMPLE LOCATION DESCRIPTION	FIXTURE TYPE	DATE OF LAST USE	TIME OF LAST USE	SAMPLE TYPE	SAMPLE VOLUME(ml)	LabName	MethodName	CONCENTRATION(ug/l)	ReportingLevel(ug/l)
			02/16/2018	06:25	Jeff Carrington	8023702-01	Kitchen 1 1st					250	PDC Laboratories, Inc.	EPA 200.8	1.79	1.00
			02/16/2018	06:25	Jeff Carrington	8023702-02	Kitchen 1 2nd					250	PDC Laboratories, Inc.	EPA 200.8	4.01	1.00
			02/16/2018	06:28	Jeff Carrington	8023702-03	Drinking Fountain 1 1st					250	PDC Laboratories, Inc.	EPA 200.8	5.83	1.00
			02/16/2018	06:28	Jeff Carrington	8023702-04	Drinking Fountain 1 2nd					250	PDC Laboratories, Inc.	EPA 200.8	2.08	1.00
			02/16/2018	06:30	Jeff Carrington	8023702-05	Drinking Fountain 2 1st					250	PDC Laboratories, Inc.	EPA 200.8	28.6	1.00
			02/16/2018	06:30	Jeff Carrington	8023702-06	Drinking Fountain 2 2nd					250	PDC Laboratories, Inc.	EPA 200.8	7.52	1.00
			02/16/2018	06:33	Jeff Carrington	8023702-07	Nurse 1 1st					250	PDC Laboratories, Inc.	EPA 200.8	2.13	1.00
			02/16/2018	06:33	Jeff Carrington	8023702-08	Nurse 1 2nd					250	PDC Laboratories, Inc.	EPA 200.8	1.27	1.00

LEAD TESTING RESULTS

Aug-18

ISBE ID	BUILDING ID	BUILDING DESCRIPTION	SAMPLE DATE	SAMPLE TIME	COLLECTED BY	SAMPLE ID NUMBER	SAMPLE LOCATION DESCRIPTION	FIXTURE TYPE	DATE OF LAST USE	TIME OF LAST USE	SAMPLE TYPE	SAMPLE VOLUME(ml)	LabName	MethodName	CONCENTRATION(ug/l)	ReportingLevel(ug/l)
			08/17/2018	07:00	NOT SPECIFIED	8083851-01	KITCHEN 1 #1					250	PDC Laboratories, Inc.	EPA 200.8	1.35	1.00
			08/17/2018	07:00	NOT SPECIFIED	8083851-02	KITCHEN 1 #2					250	PDC Laboratories, Inc.	EPA 200.8	1.09	1.00
			08/17/2018	07:05	NOT SPECIFIED	8083851-03	DRINKING FOUNTAIN 2 #1					250	PDC Laboratories, Inc.	EPA 200.8	ND	1.00
			08/17/2018	07:05	NOT SPECIFIED	8083851-04	DRINKING FOUNTAIN 2 #2					250	PDC Laboratories, Inc.	EPA 200.8	ND	1.00